

TÜV Rheinland Solar GmbH • 51101 Köln • Germany

Dr. Theodoros Makris
Phone +49 221 806-3244
Fax +49 221 806-1350
Mail solarenergy@de.tuv.com
Web www.tuv.com/solar
Cologne, 18 October 2022

Declaration Fire Test Class A according to UL 61730-2 (MST23)

Project 300100661

Manufacturer: SOLYCO Solar AG
Baseler Str. 60
12205
Berlin

Product: PV Modules

Type: SOLYCO R-TG 108p.3 (BOM D)
SOLYCO R-TG 108p.3 (BOM A)
SOLYCO R-TG 108n.3 (BOM D)

Spread of Flame and Burning Brand tests conducted on PV module types R-TG 108p.3 (BOM D, BOM A) and R-TG 108n.3 (BOM D), in accordance with UL 61730-2 (MST 23) and the test requirements of UL 790 for Class A. We hereby confirm that both tests resulted in Class A on the basis of UL 61730-2. Test results will be documented in test report 300100661.001.

Business Field Solar & Commercial Products

i. A.

18/10/2022

X 

Project Manager
Signiert von: Theodoros Makris

i. V.

18.10.2022

X 

Business Field Manager
Signiert von: Lukas Jakisch

TÜV Rheinland Solar GmbH
Am Grauen Stein
51105 Köln
Germany

Tel. +49 (0)221 806 5222
Fax +49 (0)221 806 1350
Mail solarenergy@de.tuv.com
Web www.tuv.com/solar

Board of Management
Dipl.-Kfm. Dr. Jörg Schlösser

Köln HRB 106708
UST-ID Nr.: DE256313666