

SolarEdge Technologies LTD

1 HaMada Street
4673335 Herzeliya
Israel

Kaufbeuren, 4/01/2018

Confirmation of additional model of PV Inverter

To whom it may concern,

After review of your documentation, we hereby confirm, that the following products fulfill the requirements according to BDEW, TR3 Rev. 23, TR4 Rev. 6, TR8 Rev. 6:

Products	SE25K	SE27.6K	SE33.3K
Additional Products	SE50K	SE55K	SE66.6K
Consist of	2 x SE25K	2 x SE27.6K	2 x SE33.3K
Additional Products	-	SE82.8K	SE100K
Consist of	-	3 x SE27.6K	3 x SE33.3K
Certificate Number	15-210-xx		

The additional models are made of two or three already approved models connected in parallel in a single enclosure.

Best regards



Samuel Thiboutot Rioux